

Faktaark drikkevand

Vand	2008	2009	2010	
Produktion	3.547.846	3.557.472	3.334.599	m ³
Salg	3.232.088	3.272.643	3.077.344	m ³
Tab i ledninger mm.	315.758	284.829	257.255	m ³
Tab i ledninger mm. i %	8,9	8,0	7,7	%

Ledninger				
Råvand	11,3	11,3	24,5	km
Rentvandsledninger	248	336,7	531	km

antal målere	12.041	12.278	12.211	stk
--------------	--------	--------	--------	-----

Elforbrug	1.639.471	1.934.815	1.800.381	kWh
Elforbrug/m ³	0,46	0,54	0,54	kWh/m ³

Emission				
CO ₂	739	936	808	g/kWh

Vandkvalitet	Hornshered	Haraldsborg	Agerup	Grænseværdi	
Surhedsgrad pH	7,7	7,5	7,5	mellem 7 og 8,5	pH
Hårdhed °dH	19,7	17,9	22,2		°dH
Jern Fe	<0,010	<0,005	0,044	0,1	mg/l
Mangan Mn	<0,005	<0,005	<0,005	0,02	mg/l
Ammonium NH ₄	0,006	<0,01	0,026	0,05	mg/l
Sulfat SO ₄	80	36,3	120	250	mg/l
Nitrat NO ₃	1,40	3,99	1,00	50	mg/l
Aggressivt kulilte CO ₂	<2	<2	<2	2	mg/l



