

Faktaark fjernvarme

Energi	2007	2008	2009	
Energikøb	469.197	440.695	458.604	MWh
Energisalg	375.170	349.471	366.100	MWh
Tab i ledninger mm. i kWh	94.027	91.224	92.504	MWh
Tab i ledninger mm. i %	20,0	20,7	20,2	%
Gennemsnitlige returtemperatur	49,0	49,0	49,0	°C

Ledninger	2007	2008	2009	
Hoved- og forsyningsnet	160,7	161,9	163,4	km
Stikledninger	125,8	130	126,2	km
antal målere	7.020	7.095	7.131	stk
Opvarmet areal	2.497.706	2.526.255	2.587.694	m ²
Spædevand brugt i net		17.828	15.594	m ³
Elforbrug	1.544.162	1.571.995	1.654.240	kWh
Transporteret vandmængde	13.191.000	13.496.000	13.466.274	m ³

Emission pr kWh	2007	2008	2009	
CO ₂	120,5	123,3	142,5	g/kWh
SO ₂	0,057	0,044	0,029	g/kWh
NO _x	0,252	0,203	0,157	g/kWh

Emission samlet net	2007	2008	2009	
CO ₂	56.560.068	54.341.794	65.342.822	kg
SO ₂	26.857	19.467	13.180	kg
NO _x	118.238	89.597	72.042	kg

Graddage	2007	2008	2009	
Graddage		2.254	2.525	Graddage
Normalårets graddage	2.805	2.805	2.805	Graddage



